

पत्रांक

1603 / कार्य-3 / 72

दिनांक:- 04/10/2025

सेवा में

The Shree Ram Universal School,
HS 03 Techzone -04,
Greater Noida West.

विषय:- स्कूल के पेयजल के जल नमूने की जाँच कराने के सम्बन्ध में


महोदय,

उपरोक्त विषयक, आपके पत्र संख्या शून्य दिनांक 03.10.2025 के द्वारा The Shree Ram Universal School HS 03 Techzone -04, Greater Noida West पीने के पानी का 1 नमूना आपके द्वारा अपने स्तर से एकत्र कर जाँच करने हेतु जनपदीय प्रयोगशाला गाजियाबाद में जमा कराया गया था।

उक्त जल नमूने की जाँच जनपदीय प्रयोगशाला गाजियाबाद में कर ली गयी है, जाँच रिपोर्ट संलग्न कर प्रेषित की जा रही है। जल की जाँच आपके द्वारा उपलब्ध कराये गये जल नमूने के आधार पर की गयी है। यह जाँच कानूनी प्रकरणों हेतु मान्य नहीं है।

संलग्नक:- उपरोक्तानुसार।

भवदीय



सहायक अभियन्ता

पृ0स0 एवं दिनांक उपरोक्तानुसार:-

प्रतिलिपि:- निम्नलिखित को सूचनार्थ एवं आवश्यक हेतु प्रेषित।

1. प्रयोगशाला प्रभारी, जनपदीय प्रयोगशाला, गाजियाबाद।
2. जूनियर इंजिनियर (लैब), जनपदीय प्रयोगशाला, गाजियाबाद।
3. कुमारी अंजली पोरवाल (लैब कैमिस्ट), जनपदीय प्रयोगशाला, गाजियाबाद।

सहायक अभियन्ता

प्रांक - 1603 / कार्य-3 / 72

दिनांक - 04/10/2025



TEST REPORT

District Level Water Analysis Laboratory, U.P. Jal Nigam(Rural)
Ghaziabad



TC-12972

Report No. : C/10/25-12311

Issue Date: 03/10/2025

Customer Details

Office Name and Address of the
Ref. Letter No : Date

The Shri Ram Universal School HS 03 Techzone -04, Greater Noida West.
TSRU School, 03-10-2025

Basic details of sample

District	G.B.Nagar.	Block-	-
Habitation	-	Location	The Shri Ram Universal School HS 03 Techzone - 04, Greater Noida West.
Gram Panchayat	-	Village-	Greater Noida West.
Water Source	R O Water		
Quantity of Sample	1000 ml	Sample No.-	1
Receiving Date	03.10.2025	Date of Sample Collection -	03.10.2025
Sample Depositer	Mr. Amit Sharma	Sample Collector	Mr. Amit Sharma
Analysis Start Date	03-10-2025	Analysis Completion Date	03-10-2025

Environmental Condition

Temperature: 25±2°C

Relative Humidity 50± 15%

Technical Data of Analysis

S.No.	Analysed Parameter	Units	Observed Value	Specified Values as per IS		Reference Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	PH(27.1°C)	-	7.27	6.5-8.5	6.5-8.5	IS 3025 (Part 11)Electrometric:2022
2	Turbidity	NTU	0.65	1.00	5.00	IS 3025 (Pt 10):2023
3	TDS	mg/L	114.2	500	2000	IS 3025 (Pt 16):2023
4	Chloride	mg/L	16	250	1000	IS 3025 (Part32)Argentometric:2019
5	Total Alkalinity	mg/L	56	200	600	IS 3025 (Part 23):2023
6	Total Hardness	mg/L	64	200	600	IS 3025 (Part 21):2019
7	Sulphate	mg/L	23.32	200	400	APHA 24th Edition -4500-SO4 Method E (Turbidimetric Method): 2023
8	Nitrate	mg/L	3.24	45	45	APHA 24th Edition -4500- NO3 Method B (UV Screening Method): 2023
9	Calcium as Ca	mg/L	14.4	75	200	IS 3025 (Part 40): 2023
10	Magnesium as Mg	mg/L	6.72	30	100	IS 3025 (Part 46): 2023
11	Odour	Qualitative	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5): 2018
12	Color	CU	5	5	15	IS 3025 (Part 4): 2021
13	Iron	mg/L	BDL	0.1-1.0	0.1-1.0	APHA 24th Edition -3500-Fe Method B (Phenanthroline Method) : 2017
14	Fluoride	mg/L	0.16	1.0-1.5	1.0-1.5	APHA 24th Edition -4500-F Method C (Electrode Method) : 2023

NOTE

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements
4. Sample will be stored up to 7 days from the date of issue of tests reports unless otherwise specified.
5. BDL Means Below Detaction Limit (Iron Lower Limit is 0.1)

Prepared By



(Chemist & Quality Technical Manager)
District level Water Analysis Laboratory Ghaziabad

End of The Report

पत्रांक - 1603 / कार्य - 3 / 72

दिनांक - 04/10/2025

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Date: 04/10/2025

It is certified that an inspection team headed by Ms. Anjali Pasual (Chemist) f. Gourav Mishra (SA)

(Name of officers with designation) from Distt. Lab Ghaziabad PHED

inspected the THE SHRI RAM UNIVERSAL SCHOOL HS-03 TECHZONE-4
GREATER NOIDA (WEST) GAUTAM BUDDHA NAGAR (U.P.)

(Name and Address of the school) on 03.10.2025 (date of inspection) and on the
basis of Water Test Report (Attached) bearing on C/10/25-12311 dated 03.10.2025


of U.P. Jal Nigam (Rural) Ghaziabad (PHED Lab) certified that the THE SHRI RAM UNIVERSAL SCHOOL
GREATER NOIDA (WEST)

(Name of school) has safe drinking water facilities for the students and members of staff of
the institution. School is also maintains the hygienic sanitation condition in the school
building and the campus as per norms prescribed by the Central/State/ U.P. Govt.

This certificate is valid till 03.10.2026

Signature with seal:

Name



Designation:

Assistant Engineer
Division Office
Jal Nigam (Gramin)
Ghaziabad

Name and address of the department / office: U.P. Jal Nigam (Gramin)
Ghaziabad

To

THE SHRI RAM UNIVERSAL SCHOOL

HS-03 TECHZONE-IV

GREATER NOIDA (WEST), GAUTAM BUDDHA
(Name and Address of the Institution) NAGAR

(NOTE: The certificate is to be issued by authorised officer /PHED Lab / Local bodies

